

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 24.07.2025

It is certified that an inspection team headed by N Prashanth (Name of Officers with designation) from **Sanitary Inspector** inspected the HPS, 11-1-8/2, KANTESHWAR, NIZAMABAD NORTH (M), NIZAMABAD (Name & Address of the school) on **22.07.2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **UCTIPL/HPS/TR-335/26-25** dated **19.07.2025** of **Unichem Technologies Pvt, Ltd.** (PHED Lab) certified that the HPS (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 2025-26

Signature with Seal:

Name : M. NAVI. BABU

Designation : Deputy Commissioner

Name & Address of the Office / Department :

To
HPS
11-1-8/2, KANTESHWAR,
NIZAMABAD NORTH (M), NIZAMABAD
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

UNICHEM TECHNOLOGIES INDIA PVT LTD

(ISO 9001 : 2015 Certified Company)

A New Dimension in Chemicals

Mfrs & Suppliers of : Water Treatment Chemicals & Plants



Associate Members :



TEST CERTIFICATE

Lab Ref No: UCTIPL/HPS/TR-471/25-26	Date of Issue : 19-07-2025
Name of the Party : HPS H-NO 11-1-8/2, KANTESHWAR, NIZAMABAD.	
SAMPLE DETAILS	
Sample Collection Date: 18-07-2025	Submit Date: 19-07-2025
Source of Collection : 1) RO water	Qty of sample: 250ml
KIND ATTN: - Mr. PRANAY	

TEST RESULT

S.No:	CONSTITUENTS	UNITS	RO water
1	pH Value at 25°C		6.7
2	Electrical conductivity @ 25°C, $\mu\text{S}/\text{cm}$	Micro	82
3	Total Dissolved solids, mg/l	mg/l	55
4	Turbidity, (NTU)	NTU	0.1
5	Colour, (Hazen Units)		01
6	Odour		Agreeable
7	Total Hardness as CaCO_3 , mg/l	mg/l	10
8	Alkalinity to Phenolphthalein as CaCO_3 , mg/l	mg/l	Nil
9	Alkalinity to methyl orange as CaCO_3 , mg/l	mg/l	60
10	Calcium as Ca, mg/l	mg/l	7.8
11	Magnesium as Mg, mg/l	mg/l	2.28
12	Sodium as Na, mg/l	mg/l	12.8
13	Potassium as K, mg/l	mg/l	4.7
14	Chloride as Cl, mg/l	mg/l	<10
15	Sulphate as SO_4 , mg/l	mg/l	15.3
16	Nitrate as NO_3 , mg/l	mg/l	0.28
17	Fluoride as F, mg/l	mg/l	0.01
18	Total Silica as SiO_2 , mg/l	mg/l	<2.0
19	Iron as Fe, mg/l	mg/l	<0.1
MICROBIOLOGICAL			
20	Total coliform Bacteria, /100ml	ml	Absent
21	Escherichia coli, /100ml	ml	Absent

Suggestions and Remarks:

1. In RO water all parameters are under control

For UNICHEM TECHNOLOGIES INDIA PVT LTD
LAB INCHARGE



UNICHEM TECHNOLOGIES INDIA PVT LTD

Head Office : 1-9-8/1/J, Behind SBI Bank, Ramnagar, Hyderabad - 500 020.

Cell : +91 8185888831, 8185822220, Tel : 8977504404

Factory : Plot No. 122, Chengicherla(V), Near Cherlapally, Ghatkesar(M), R.R Dist - 500 092.

Branch Off : Vishakhapatnam, Vijayawada, Kakinada, Bangalore.